



# Application form for the issue of an Electricity Generation Licence

by the Essential Services Commission of SA under the  
Electricity Act 1996

August 2017

Enquiries concerning an application form should be addressed to:

Essential Services Commission

GPO Box 2546

Adelaide SA 5001

Telephone: (08) 8206 2000

Toll-free: 1800 639 192 (SA and mobiles only)

E-mail: [esccsa@escosa.sa.gov.au](mailto:esccsa@escosa.sa.gov.au)

Web: [www.escosa.sa.gov.au](http://www.escosa.sa.gov.au)

## Table of contents

Licence requirements and conditions .....	1
Generation operations which require a licence.....	1
Mandatory licence conditions.....	1
Additional technical licence conditions.....	1
Annual licence fees .....	2
Use of this form and applicant's responsibilities .....	3
Application fees.....	3
How to lodge an application.....	3
Consultation and Confidentiality .....	3
Further information.....	4
Licence Application Form .....	1
1 The Applicant.....	1
1.1 Identity of Applicant .....	1
1.2 Legal Identity of Applicant.....	1
1.3 Address and Contact Details of Applicant .....	1
1.4 Contact Person on behalf of Applicant .....	1
1.5 Contact Person for Licence Fees .....	2
1.6 Diagram of Corporate or other Structure .....	2
2 The Licence.....	3
2.1 Date from which Licence is sought.....	3
2.2 Nature and scope of operations for which Licence is sought.....	4
3 Suitability of applicant to hold a licence .....	5
3.1 Standard of honesty and integrity shown by Applicant.....	5
3.2 Standard of honesty and integrity shown by Officers and major shareholders of Applicant ...	6
3.3 Names and addresses of the Officers of Applicant .....	6
3.4 Names and addresses of major shareholders of Applicant.....	7
3.5 Details of the group members .....	8
3.6 Additional information .....	8
3.7 Financial resources available to the Applicant .....	9
3.8 Additional Details of Structure of Applicant .....	9
3.9 Human resources available to the Applicant .....	10
3.10 Technical resources available to the Applicant .....	11
3.11 Quality of Electricity Produced/Connection Agreement.....	11
3.12 Risk Management.....	12
3.13 Development Act Approval.....	12
3.14 Registration with AEMO.....	12
3.15 Licences held by the Applicant in other Australian jurisdictions.....	13
3.16 Previous unsuccessful licence applications in other Australian jurisdictions .....	13
3.17 Licences held by Associates of the Applicant.....	14
3.18 Compliance Plans.....	14

3.19	Additional Information .....	15
4	Factors specified in the Essential Services Commission Act 2002.....	16
5	Application fees .....	16
6	Declaration .....	17
	Attachment 1.....	17
	2017 model licence conditions for new generators .....	17
	Interpretation of this schedule.....	18
	Disturbance ride through capability.....	18
	Voltage control capability .....	21
	System strength .....	21
	Active power control capability.....	21
	System restoration .....	23

## Licence requirements and conditions

It is essential that licence applicants read the Essential Services Commission's (**Commission**) Advisory Bulletin No 4 – "Licencing Arrangements for the Electricity and Gas Supply Industries" before they fill out this form. This Bulletin is available on the Commission website [www.escosa.sa.gov.au](http://www.escosa.sa.gov.au) under electricity/licensing.

### Generation operations which require a licence

Section 15(2)(a) of the *Electricity Act 1996 (Act)*<sup>1</sup> is explicit in that it requires a person that carries on the operation of the generation of electricity to hold a licence. This requirement applies to all generators with the exception of a generator that can rely on:

- (1) one of the statutory exemptions specified in the Electricity (General) Regulations 1997 (**Regulations**) outlined below;
- (2) an individual exemption issued by the Commission (with the approval of the Minister) pursuant to section 80(1) of the Act; or
- (3) an exemption made by Governor under a regulation pursuant to section 98(2)(e) of the Act.

Pursuant to Regulations 6(1) and (2), the following generators are exempt from the requirement to hold a generation licence:

- ▶ a generator whose generating plant has a rated nameplate output of 100kVA or less;
- ▶ a generator that does not supply electricity for reward to or by means of a transmission or distribution network;
- ▶ a generator that generates electricity for the sole consumption of that generator or a designated body (such bodies must be designated by the Minister<sup>2</sup>); or
- ▶ a generator that generates electricity for a person at a premises occupied or used by the person as a tenant or licensee (whether directly or indirectly) of the generator (or a designated body) where that person is not charged for the supply of electricity except by a licensed retailer/generator or as an unspecified part of rent or charges for the occupation or use of the premises.

It is important for generators (or proposed generators) to carefully consider whether they can rely on a statutory exemption from the requirement to be licensed. If the reliance on a statutory exemption is queried by the Commission, the onus to provide evidence that a particular exemption can be relied upon is on the relevant generator.

In addition, in the event that the operations of a generator change so that it can no longer rely on one of the three exemptions specified above, it will need to apply to the Commission for a generation licence immediately in order to continue those operations.

### Mandatory licence conditions

Sections 21(1) and 22 of the Act requires the Commission to place certain mandatory conditions in generation licences. The Commission strongly recommends that applicants review these mandatory conditions. Applicants must be familiar with the relevant conditions and confident that they can comply with the conditions.

### Additional technical licence conditions

Additional technical licence conditions apply to all new electricity generators seeking to connect to the South Australian power system. Applicants for a generation licence should familiarise

<sup>1</sup> Available at <https://www.legislation.sa.gov.au/LZ/C/A/ELECTRICITY%20ACT%201996.aspx>

<sup>2</sup> To date, the Minister for Energy and Resources has not designated any bodies for the purposes of Regulations 6(1).

themselves with the Commission's Inquiry into the licensing arrangements for generators in South Australia final report, available on the Commissions website.<sup>3</sup>

Model licence conditions reflecting the Inquiry findings and conclusions have been developed and are available in Appendix 1. The model conditions will be applicable to all new applications, having regard to advice from the Australian Energy Market Operator (**AEMO**) on the specific circumstances of individual applications received.

Depending on the specific characteristics of a given generation project, the model conditions may be varied to the degree necessary to ensure that South Australian consumers' long-term interests with respect to the price, quality and reliability of electricity services are protected.

### Annual licence fees

Holding a licence incurs annual licence fees. The licence fees determined by the Minister for Resources and Energy are administered by the Commission. At annual intervals, the Commission, on behalf of the Minister, will send to each licensee, depending on the category within the sector, an invoice for the licence fee. Licence fees are to be paid on receipt of an invoice via one of the payment options set out in the invoice.

The initial licence will not be issued until the first annual licence fee (or approved licence fee instalment) has been paid.

---

<sup>3</sup> Refer: <http://www.escosa.sa.gov.au/projects-and-publications/projects/inquiries/inquiry-into-licensing-arrangements-under-the-electricity-act-1996-for-inverter-connected-generators/inquiry-into-licensing-arrangements-under-the-electricity-act-1996-for-inverter-connected-generators>



supporting information will be made available on the Commission's website and in hard copy from the Commission's office for this purpose.

If applicants believe that they are providing confidential information when completing this form they should write "this information is confidential" after any such information. It is the applicant's responsibility to ensure this is clearly highlighted on the form. Applicants should also provide a 'non-confidential' version of the form capable of publication on the Commission's website.

The Commission will use information supplied in applications and in support of applications in accordance with the requirements of Part 5 of the Essential Services Commission Act 2002. Applicants claiming confidentiality are encouraged to familiarise themselves with Part 5. Applicants should note that the Commission may disclose confidential information in some circumstances.

#### Further information

Applicants should note that the Commission may ask applicants who have submitted an application form to provide further information to the Commission, or to clarify the information that they have already provided if required.

Please note that, in the event that an application lacks sufficient detail and the Commission is required to request additional information from an applicant, delays in the assessment of the application may occur.

# Licence Application Form

## 1 The Applicant

Applicants must answer all questions in this section.

### 1.1 Identity of Applicant

State the full name of the applicant. The applicant is the person who will be undertaking the electricity generation operations that will be the subject of the licence. Joint applicants should each complete an application form, and submit their application forms at the same time, with a covering letter explaining that a joint application is being made.

**Name:** SOUTH AUSTRALIAN PRODUCE MARKET LIMITED (ABN 49 008 129 566) ...

### 1.2 Legal Identity of Applicant

Provide information about the applicant, (i.e. whether the applicant is a natural person, private limited company or partnership, etc). If the applicant is a body corporate, please also state the jurisdiction in which the applicant is registered, and the applicant's ABN/ACN.

The Applicant, the South Australian Produce Market Limited is a public company limited by shares located in South Australia.....

### 1.3 Address and Contact Details of Applicant

**Business Address:** Burma Road, Pooraka .....

**State:** SA..... **Post Code:** 5095 .....

**Postal Address (if different to Business Address):**

**State:** ..... **Post Code:** .....

**Telephone:** 08 8349 4493..... **Facsimile:** 08 8349 6574.....

**E-mail:** enquiries@saproducemarket.com.au.....

### 1.4 Contact Person on behalf of Applicant

The full name, title and contact details of a person to whom the Commission can direct enquiries and correspondence about the application.

**Full Name:** Damian Edwards .....

**Title:** Energy Specialist.....

**Business Address:** CQ Partners .....

143/220 Greenhill Rd .....

**State:** SA..... **Post Code:** 5063 .....

**Postal Address (if different to Business Address):**

State: ..... Post Code: .....  
 Telephone: (08) 8464 0012 ..... Facsimile: (08) 8221 6204 .....  
 E-mail: damian@cqpartners.com.au .....

1.5 Contact Person for Licence Fees

The full name and/or title of the person to whom the Commission can direct enquiries and correspondence about licence fees.

Full Name: John Edwards .....  
 Title: Financial Controller .....  
 Business Address: Burma Road, Pooraka .....

State: SA ..... Post Code: 5095 .....

Postal Address (if different to Business Address):

State: ..... Post Code: .....  
 Telephone: 08 8349 4493 ..... Facsimile: .....  
 E-mail: john@saproducemarket.com.au .....

1.6 Diagram of Corporate or other Structure


Please attach with this application form details of the corporate or other structure, including details of any related companies within the meaning of the Corporations Act 2001; and a diagram of the organisational chart, including composition of the board, management and other key personnel responsible for the key functions of the business.

The South Australian Produce Market is a public company, limited by shares. Ownership is predominantly held by fresh produce growers, wholesalers and retailers. However, there are non-produce industry shareholders. The produce industry shareholders hold over 50% of the shares in the company. The constitution of the company requires that industry control be maintained.

The structure is shown in the diagram below.



The diagram below illustrates the SA Produce Market's organisational structure.



## 2 The Licence

Applicants must answer all questions in this section.

### 2.1 Date from which Licence is sought

Applicants should usually allow the Commission a minimum of 12 weeks to consider an application, as a public consultation period of at least four weeks forms part of the Commission's consideration of licence applications. If the applicant seeks to have the licence issued by a certain date, provide this date. Please note that the Commission does not undertake to issue the licence by this date.

The applicant seeks to have the Generation Licence issued from **1 November 2018** or as soon as practically possible. ....

.....

.....

.....





3.2 Standard of honesty and integrity shown by Officers and major shareholders of Applicant

Applicants should address responses to this question in the same manner as 3.1 above except here it relates to officers and major shareholders of the applicant.

Please also supply details of any policies and procedures addressing the probity and competence of officers and other key management staff.

None of the Officers listed in Section 3.3 hereunder have displayed any prior misconduct, or experienced refusal or suspension from licensing or professional membership. Furthermore, none of the Officers listed have an actual or potential conflict of interest likely to affect their ability to carry out their role. ....

3.3 Names and addresses of the Officers of Applicant

State the names and addresses of the officers of the applicant. "Officers" of the applicant include the applicant's directors and secretary, and other persons who make or participate in making decisions that affect a substantial part of the business of the applicant.

Full Name: Angelo Demasi .....  
Date of Birth: 05/11/1968 ..... Office Held: Chief Executive Officer  
Address: C/- SA Produce Market Limited, Burma Road .....  
State: South Australia ..... Post Code: 5095 .....

Full Name: David Schirripa .....  
Date of Birth: 14/12/1969 ..... Office Held: Director/Chairman  
Address: C/- Schirripa Evans Lawyers, 185 Fullarton Road, Dulwich .....  
State: South Australia ..... Post Code: 5065 .....

Full Name: Antonio Ceravolo .....  
Date of Birth: 30/08/1966 ..... Office Held: Director .....  
Address: 374 Lobethal Road .....  
State: Ashton ..... Post Code: 5137 .....

(attach additional pages if necessary)

3.4 Names and addresses of major shareholders of Applicant

State the full names and addresses of the major shareholders of the applicant

Name: Pasquale Scalzi .....  
Date of Birth 16/02/1949: ..... Office Held (if applicable): Director.....  
Address: 20 Downer Avenue .....  
.....  
State: Campbelltown..... Post Code: 5074 .....

Name: Nicola Minicozzi .....  
Date of Birth (if applicable): ..... Office Held (if applicable): Director/Dep. Chair ..  
Address: 17 Hackney Road, Hackney .....  
.....  
State: SA..... Post Code: 5069 .....

Name: Daniele De Ieso .....  
Date of Birth (if applicable): ..... Office Held (if applicable): Director.....  
Address: 28 Stradbroke Road, Newton .....  
.....  
State: SA..... Post Code: 5074 .....

Name: Girolamo Fragnito .....  
Date of Birth (if applicable): ..... Office Held (if applicable): Director.....  
Address: 198 Payneham Road Evandale .....  
.....  
State: SA..... Post Code: 5069 .....

Name: Michael Ruggiero.....  
Date of Birth (if applicable): ..... Office Held (if applicable): Director.....  
Address: 139 Frome Street, Adelaide.....  
.....  
State: SA..... Post Code: 5000 .....

Name: Christine Scalzi .....  
Date of Birth (if applicable): ..... Office Held (if applicable): Director.....  
Address: 8 Bedford Street.....  
.....  
State: SA..... Post Code: 5068 .....

Name: Derrick Patterson.....  
 Date of Birth (if applicable):..... Office Held (if applicable): Director.....  
 Address: 29 Lerwick Avenue, Hazelwood Park .....  
 .....  
 State: SA..... Post Code: 5066 .....

### 3.5 Details of the group members

This is information about entities controlled by the applicant, or by the ultimate parent entity of the applicant (if applicable).

The applicant controls the following wholly owned subsidiaries:

- APML No One Pty Ltd ACN 107 271 885
- APML No Two Pty Ltd ACN 117 136 133
- Australian Produce Markets Pty Ltd ACN609 015 269
- Adelaide Market Pty Ltd ACN 164 607 103
- 9 Burma Road Pooraka Pty Ltd ACN 608 560 050
- Australian Produce Cases & Recycling Pty Ltd CAN 608 561 057
- 5101 Commerce Crescent Pty Ltd ACN 604 957 691
- 5102 Commerce Crescent Pty Ltd ACN 604 957 888
- APML Exports No 2 Pty Ltd ACN 609 016 015

### 3.6 Additional information

Please answer the following questions.

- ▶ Is the applicant a resident of, or does it have permanent establishment in, Australia? Where the answer to this question is no, please provide further detail.

Yes.....  
 .....  
 .....

- ▶ Is the applicant under external administration (as defined in the Corporations Act 2001) or under a similar form of administration under any laws applicable to it in any jurisdiction? Where the answer to this question is yes, please provide further detail.

No.....  
 .....  
 .....

- ▶ Is the applicant immune from suit in respect of the obligations under the Electricity Act 1996? Where the answer to this question is yes, please provide further detail.

No.....  
 .....  
 .....

- ▶ Is the applicant capable of being sued in its own name in a court of Australia? Where the answer to this question is no, please provide further detail.

Yes .....

.....

.....

.....

(attach additional pages if necessary)

### 3.7 Financial resources available to the Applicant

Provide information about the financial resources available to the applicant. If the applicant is a company, please also enclose:

- ▶ copies of all audited profit and loss statements and balance sheets for the last three financial years (including all notes), and
- ▶ director's declaration that the financial statements comply with accounting standards, give a true and fair view, have been made in accordance with the Corporations Act and that there are reasonable grounds to believe the company/entity will be able to pay its debts as and when they fall due; and
- ▶ the director's report and the audit opinion.

If the applicant is a subsidiary company, please also provide:

- ▶ copies of all audited profit and loss statements and balance sheets of the applicant's parent company for up to the last three financial years.

The applicant should also submit copies of:

- ▶ its business plans including at least strategic direction and objectives, identified opportunities in the market place and forecast results; and
- ▶ evidence of capital and liquidity support in place, including any bank or cross guarantees, to support the business and evidence of negotiations with the network service provider concerning credit support arrangements.

Please see attached Annual Reports for 2017, 2016 and 2015 which should provide the above requested information. ....

.....

.....

.....

### 3.8 Additional Details of Structure of Applicant

If the applicant is part of a group of related companies, and/or party to a partnership, joint venture or alliance agreement with another company, please provide:

- ▶ contractual arrangements (e.g. alliance contracts, associate contracts, establishment contracts) that define relationships within the group – including shared resources, guarantees, revenue flows, obligations and or responsibilities.

The application has a number of wholly owned subsidiaries as listed in section 3.5. ....

.....

.....

.....  
.....  
**3.9 Human resources available to the Applicant**

Provide information about the human resources available to the applicant. This includes:

- ▶ the experience and qualifications of those employees outlined in the organisational chart (see point 1.6); and
- ▶ if the applicant will employ contractor/s to assist with the licensed operations, the name of that contractor/s, details about the experience of the contractor/s in such operations and details of the processes in place to ensure the contractor/s complies with the regulatory obligations imposed by the licence.

The Applicant presently holds a Retail Exemption and Network Exemption with the AER and has so since 2013. Over 130 separate customers are managed within the embedded network with South Australian Produce Market Limited' staff undertaking the ongoing administration of selling electricity to their customers through metering, billing and management.

The South Australian Produce Market Limited is well resourced to manage their obligations covering retailing, embedded network management, billing and compliance with their electricity retail exemption, network exemption and generator licence.

Angelo Demasi (CEO) was appointed in March 2000 and brings over 25 years senior management experience from the fresh produce, meat, bakery, manufacturing and retail industries. Tertiary qualified in Accounting and Management, a Fellow of the Australian Institute of Management and a Fellow member of the Institute of Public Accountants, Angelo oversees the general day-to-day operations of the Market, which includes mentoring staff, strategic planning, Corporate Governance, property development and developing relations with commercial and Government agencies. With an active involvement with the Central Markets Association of Australia, Angelo has addressed issues that affect the horticulture and wholesale market industries and undertaken extensive research on central markets within Australia and Europe. He has also experience in service and policy formulation at State Government, Federal Government and wholesale market levels. Angelo has extensive industry representation and has been a member of a number of related committees including the Premier's Food Council, Chair of the Primary Industries Horticultural Industry Development Board, Primary Industries Food Care Project, SA Italian Chamber of Commerce, the South Australian Fruit and Vegetable Coalition, the Plant Health Consultative committee and is on the tax committee for the Property Council of Australia.

All operational and compliance aspects will be managed by Karen Butler (Facilities & Compliance Manager), a highly experienced project manager who has a team of staff to support her role. Karen was appointed in March 2008 and brings over 17 years' experience in facility management, including experience in the United Kingdom with Unilever and more recently with the Adelaide Central Market and Knight Frank in South Australia. With qualifications in WHS obtained in Australia and the United Kingdom, Karen's primary role is to manage the day-to-day operations of the market to ensure trading is undertaken in a safe and efficient manner. Other duties include managing security, tenancies, parking, cleaning, repairs and maintenance, capital expenditure and general market user enquiries.

All financial and administrative aspects will be Managed by John Edwards (Financial Controller). John has over 25 year's accounting experience in roles ranging from financial controller to company secretary across many industries.

.....  
.....  
.....  
.....

.....

### 3.10 Technical resources available to the Applicant

Applicants for a generation licence are asked to provide details about the availability of technical resources to be used in carrying out the operations for which a licence is sought. The information should include details about the technically qualified staff available to the applicant and (if relevant) details of experience gained in similar operations.

Where applicants are relying on a third party to provide staff and resources to meet the technical requirements of the generation licence, please provide:

- ▶ a list of all functions and activities being proposed to outsource;
- ▶ details of any formal agreement/s to provide services, including confirmation that the third party possess relevant technical competencies to conduct the proposed activities;
- ▶ a summary of the third party's technical capacity to meet relevant obligations, including relevant accreditations; and
- ▶ a summary of the third party's experience and knowledge in the relevant area.

The South Australian Produce Market Limited will utilise its existing contracts with Azzo and Access Datacom for the provision of communications infrastructure to manage the settlements and interaction with the NEM including LV metering and power system monitoring. Azzo currently provides LV metering and embedded network monitoring with Access Datacom providing the initial installation and ongoing maintenance of the communications infrastructure at the South Australian Produce Market Limited site.

The South Australian Produce Market Limited has been using Schneider Electric's StruxtureWare Power Monitoring Expert platform which has all of the connection points required to easily integrate into the new microgrids control scheme. The project will install StruxtureWare PowerSCADA Expert, which is another additional module in the same suite of EcoStructure products which will seamlessly integrate with the HV SCADA and Control aspects of this microgrid acting as the central Microgrid Controller.

The project has been endorsed by the SA Government through receipt of grant funding through the Energy Productivity Program. The ongoing O&M components of this project have been contracted to Autonomous Energy whom are also contracted to provide the EPC component of this project. Autonomous Energy is an award winning national sustainable energy Engineering, Procurement and Construction (EPC) company that has been in operation since 2003. Autonomous Energy have experience in medium-scale solar PV installations over 1MW, having installed Australia's largest carpark solar PV at the University of Southern Queensland. ....

.....

.....

.....

.....

.....

.....

.....

### 3.11 Quality of Electricity Produced/Connection Agreement

The Commission may not issue a generation licence unless it is satisfied that the generating plant (or proposed generating plant) will generate electricity of the appropriate quality for the relevant transmission or distribution network. The Commission will be satisfied that the

electricity is of an appropriate quality if the applicant has entered into a connection agreement which meets the Commission's technical requirements with the licensed operator of the relevant transmission or distribution network. Applicants are therefore required to submit a copy of such a connection agreement.

.....  
~~SA Power Networks connection agreement process currently being undertaken (have submitted connection enquiry)~~ .....

3.12 Risk Management

Provide confirmation and reasonable evidence that the applicant's management has identified the risks associated with electricity operations and has established, utilises and relies upon risk management systems and processes which are adequate, accurate and current to address those risks. A copy of the applicant's risk management strategy should be submitted.

~~Currently being developed~~ .....

3.13 Development Act Approval

Please advise if the applicant has or is applying for approval under the Development Act 1993 (SA). If so, provide details, including the date on which approval was or will be granted.

Development Approval granted by the City of Salisbury on 2 May, 2018

(Development number: 361/2049/2017/1B).....

3.14 Registration with AEMO

Please advise if the applicant will apply to register with AEMO. If so, provide details. Applicants for a wind generation licence should note that registration as a semi-scheduled market participant is required for all new generators and all expansions to existing wind generation plant.

As the initial commissioning of the project (2.34MW solar + 2.4MW diesel) is under AEMO's 5MW nameplate threshold for registration, the project qualifies for an automatic exemption from generator registration with AEMO.....

.....

.....

.....

.....

.....

.....

.....

.....

**3.15 Licences held by the Applicant in other Australian jurisdictions.**

If the applicant holds, or has previously held, electricity and/or gas licences in other Australian jurisdictions please provide details. If a licence previously held has been suspended or cancelled, please provide details.

Not applicable.....

.....

.....

.....

.....

.....

.....

.....

**3.16 Previous unsuccessful licence applications in other Australian jurisdictions**

Please state whether the applicant has applied for an electricity or gas licence in another Australian jurisdiction and not been issued with a licence, and provide details if relevant.

Not applicable.....

.....

.....

.....

.....

.....

.....

.....

.....

.....

.....

.....

.....

.....

3.17 Licences held by Associates of the Applicant

If an associate of the applicant (within the meaning of the Corporations Act) holds an electricity or gas licence in South Australia or in other Australian jurisdictions, please provide details.

Not applicable.....  
.....  
.....  
.....  
.....  
.....  
.....

3.18 Compliance Plans

Applicants are required to submit a copy of their Compliance Plan which demonstrates how the compliance systems the applicant has (or will have) in place will ensure compliance with all of the applicable regulatory obligations imposed by the relevant licence.

~~Currently being developed~~



## 4 Factors specified in the Essential Services Commission Act 2002

In considering a licence application, the Commission must have as its primary objective protection of the long term interests of consumers with respect to the price, quality and reliability of electricity supply, and must also have regard to the need to:

- (a) promote competitive and fair market conduct;
- (b) prevent misuse of monopoly or market power;
- (c) facilitate entry into relevant markets;
- (d) promote economic efficiency;
- (e) ensure consumers benefit from competition and efficiency;
- (f) facilitate maintenance of the financial viability of regulated industries and the incentive for long term investment;
- (g) promote consistency in regulation with other jurisdictions.

If the applicant believes that information about their application would assist the Commission in its consideration of these factors, the applicant should provide such information below.

The generation infrastructure being implemented by the South Australian Produce Market Limited will enable South Australia's food producers, wholesalers and retailers to access cheaper electricity without the need to procure from established, vertically integrated retailers whom have monopolised the Australian electricity market over recent years.

The technology will future proof the supply of electricity at the site facilitating the supply of sustainable, renewable electricity while providing a secure supply in the event of a failure in grid supply. The utilisation of battery technology will enable the site to provide system security services to the electricity market in the future if required.....

.....

.....

.....

.....

.....

.....

.....

## 5 Application fees

Applicants for a licence must pay to the Commission an application fee fixed by the Minister for Energy from time to time. This fee is presently set at \$1,000 per licence. Please enclose this fee with the application. An application cannot be considered until this fee has been received and cannot be refunded.

## 6 Declaration

All information in this application for the issue of a licence to authorise electricity generation operations in the electricity supply industry in South Australia must be verified by a Statutory Declaration of the applicant, in accordance with the provisions of the *Oaths Act 1936 (SA)*<sup>4</sup>, stating that the information contained in the application is true and correct to the best of the applicant's knowledge, information and belief.

Where the applicant is a body corporate, evidence of the relevant authority of the declarant to sign on behalf of the body corporate must also be provided to the Commission.<sup>5</sup>

### Statutory Declaration


I DAVID SCHIRIPA.....

of 185 FOLLARTON ROAD DOLWICH SA 5065.....

do solemnly and sincerely declare that the information contained in this Application for the issue of a licence to authorise electricity generation operations in the electricity supply industry in South Australia is true and correct to the best of my knowledge information and belief.

And I make this solemn declaration conscientiously believing the same to be true, and by virtue of the provisions of the *Oaths Act 1936*.

Date 14 NOVEMBER 2018.....

Signature .....

(Where the applicant is a body corporate, the declaration must be made by a person authorised by body corporate to sign on its behalf)

Declared at: DOLWICH..... this 14<sup>th</sup> day of NOVEMBER 2018

Before me: .....

(Signature of Justice of the Peace or other person authorised under the *Oaths Act 1936*)

FELICE ARLOTTA  
A Commissioner for taking Affidavits  
in the Supreme Court of South Australia

## Attachment 1

### 2017 model licence conditions for new generators

<sup>4</sup> or equivalent legislation in other Australian jurisdictions.

<sup>5</sup> The Commission will accept a copy of a Board minute (or circulating resolution) giving approval for the declarant to sign on behalf of the applicant as evidence of the relevant authority.

## Interpretation of this schedule

### 1. Interpretation

1.1. Terms used in this schedule and also in the National Electricity Rules (NER) have the same meaning in this schedule as they have in those rules (unless otherwise specified or unless the context otherwise requires).

1.2. For the purposes of this schedule, the term:

**Commission** - means the Essential Services Commission, established under the Essential Services Commission Act 2002.

**continuous uninterrupted operation** means that, for voltage disturbances within the continuous operating range (that is, connection point voltage fluctuating within 90 percent and 110 percent of normal voltage), active power must be maintained (unless there has been a change in the intermittent power source) and reactive power must be managed to meet voltage control requirements.

## Disturbance ride through capability

### 2. Disturbance ride through capability -- general requirements

2.1. The non-synchronous generating system must meet the following requirements:

- (a) The low voltage ride-through activation threshold (LVRT), as measured at the low voltage (LV) terminals of the generating units and dynamic reactive support plant (as applicable), must not be less than 85 percent of nominal voltage.
- (b) The generating system must maintain continuous uninterrupted operation for voltage disturbances as specified in clauses 3, 7 and 8.
- (c) Where LVRT and high voltage ride-through (HVRT) requirements in the NER are specified in respect of the generating system's connection point, the withstand capability of individual generating units is to be determined at the LV side of the generating unit's transformer. All individual generating units must remain connected for connection point voltages within the LVRT/HVRT withstand requirements, irrespective of the generating system's transformer tap position.

### 3. Disturbance ride-through (reactive current injection)

- 3.1. The generating system must supply additional capacitive reactive current (reactive current injection) of up to 4 percent of the maximum continuous current of the generating system (in the absence of a disturbance) for each 1 percent reduction of connection point voltage below 90 percent of normal voltage, as shown in Table 1. This requirement applies at the LV terminals of the generating units and dynamic reactive support plant (as applicable) for power system disturbances resulting in a voltage reduction of up to 100 percent of normal voltage at the connection point.
- 3.2. The generating system must supply additional inductive reactive current (reactive current absorption) of up to 6 percent of the maximum continuous current of the generating system (in the absence of a disturbance) for each 1 percent increase in connection point voltage

above 110 percent of the normal voltage, as shown in Table 1. This requirement applies at the LV terminals of the generating units and dynamic reactive support plant (as applicable).

- 3.3. The reactive current injection must be maintained until the connection point voltage returns to within the range of 90 percent to 110 percent of normal voltage.

Table 1: Reactive current injection requirements

Reactive current response	Current injection gain (%)	Current absorption gain (%)	Minimum amount of contribution as percentage of rated current	Speed of contribution	
				Rise time (millisecond)	Settling time (millisecond)
Synchronous	4	6	250	30	N/A
Non-synchronous	4	6	100	30	60

- 3.4. The amount of reactive current injection required may be calculated using phase-to-phase, phase-to-ground, or sequence components of voltage. For the last method, the ratio of negative-sequence to positive-sequence current injection must be X.<sup>6</sup>

- 3.5. The generating system must comply with the following response characteristics for reactive current injection:

- (a) A rise time no greater than 30 milliseconds and a settling time no greater than 60 milliseconds applies to reactive current injection requirements.<sup>7</sup>
- (b) The reactive current injection requirements described above apply for all pre-disturbance reactive power control modes (voltage control, power factor control and reactive power control).<sup>8</sup>
- (c) The reactive current response must be adequately damped as defined in the NER.
- (d) Upon occurrence of a fault, reactive power consumption must not exceed 5 percent of maximum continuous rated current of the generating system and must be limited to the rise time duration set out in Table 1.
- (e) The post-fault reactive power contribution of the generating system must be sufficient to ensure that the connection point voltage is within the following ranges for continuous uninterrupted operation:
  - (i) voltages over 110 percent for the durations permitted under NER clause S5.1a.4;
  - (ii) 90 percent to 110 percent of normal voltage continuously;
  - (iii) 80 percent to 90 percent of normal voltage for a period of at least 10 seconds; and
  - (iv) 70 percent to 80 percent of normal voltage for a period of at least 2 seconds.

#### 4. Disturbance ride through (active power injection requirements)

<sup>6</sup> The exact ratio of negative-sequence to positive-sequence current injection will be specified by the Commission at the time the licence is issued.

<sup>7</sup> The settling time requirement does not apply to synchronous generators.

<sup>8</sup> This requirement does not apply to synchronous generators.

- 4.1. The generating system must be capable of restoring active power to at least 95 percent of the level existing just prior to a fault within X milliseconds after disconnection of the faulted element.<sup>9</sup>
- 4.2. Upon occurrence of a fault, a generating system's transient active power consumption must not exceed one power frequency cycle and must not exceed 5 percent of the maximum continuous rated current of the generating system.

**5. Multiple low voltage disturbance ride-through**

- 5.1. The generating system, including, but not limited to, each of its generating units and dynamic reactive power support plant, must be capable of withstanding both of the following within a five minute interval:
  - (a) Any combination of voltage disturbances causing the voltage at the respective low voltage (LV) terminals of the equipment to drop below 85 percent of the nominal voltage for a total duration of 1,500 milliseconds regardless of disturbance type, duration, and residual voltage at the generating unit's terminals. The total number of voltage disturbances for which successful ride-through is required is limited to 15. Each fault can be a solid fault resulting in 100 percent voltage drop at the connection point with duration not exceeding the longest time expected to be taken for the breaker fail protection system to clear the fault, as set out in Table S5.1a.2 of the NER.
  - (b) A single worst-case long-duration shallow voltage disturbance, causing the voltage at the connection point to drop to 70- 80 percent of the normal voltage for a total duration of 2,000 milliseconds.
- 5.2. Subject to compliance with the requirements in clause 5.1, the generating system, including, but not limited to, each of its generating units and dynamic reactive power support plant, is not required to withstand any additional voltage variation exceeding  $\pm 10$  percent of nominal voltage experienced at the respective LV terminals within 30 minutes from the commencement of the first variation.<sup>10</sup>

**6. Disturbance ride-through (high voltage disturbance ride-through)**

- 6.1. The generating system must have a level of over-voltage withstand capability consistent with the levels shown in Table 2.<sup>11</sup>
- 6.2. The generating system must maintain continuous uninterrupted operation for temporary over voltage durations as specified in Table 2.

Table 2: Required over voltage withstand capability

Temporary overvoltage (% of normal voltage)	110–115	>115–120	>120–125	>125–130	>130–140
Duration(s)	1,200	20	2	0.2	0.02

**7. Disturbance ride-through (partial load rejection)**

- 7.1. The non-synchronous generating system must be capable of continuous uninterrupted operation during and following a power system load reduction of 30 percent from its

<sup>9</sup> The exact active power recovery time will be specified by the Commission at the time the licence is issued and will be between 100 and 500 milliseconds.

<sup>10</sup> For synchronous generators, consideration will be given to the physical limitations of the plant. This may require a variation to this condition, to be determined by Commission at the time of issuing of the licence.

<sup>11</sup> Unless otherwise specified by the Commission at the time the licence is issued.

pre-disturbance level or equivalent impact from separation of part of the power system in less than 10 seconds, provided that the loading level remains above minimum load.

#### **8. Disturbance ride-through (frequency disturbance ride-through)**

8.1. The generating system must be capable of continuous uninterrupted operation for any combination of the following rates of change of frequency:

- (a)  $\pm 4$  Hz/s for 250 milliseconds
- (b)  $\pm 3$  Hz/s for 1 second, until such time as power system frequency breaches the extreme frequency excursion tolerance limits.<sup>12</sup>

#### **9. Disturbance ride-through (voltage phase angle shift)**

9.1. The generating system must not include any vector shift or similar relay/protective function acting upon voltage phase angle which might operate for phase angle changes less than 20 degrees.

### Voltage control capability

#### **10. Voltage control capability**

- 10.1. The generating system must be capable of being controlled by a fast-acting, continuously variable, voltage control system which must be able to receive a local and remote voltage set point.
- 10.2. The generating system must be capable of operating at either a set reactive power level or a set power factor, which must be able to be set locally or remotely at any time.
- 10.3. The voltage, power factor and reactive power control mode of the generating system must be capable of:
  - (a) being overridden by the disturbance ride through requirements specified in clauses **Error! Reference source not found.** to 9 (inclusive) during power system voltage disturbances, and
  - (b) automatically reverting to power factor or reactive power mode when the disturbance has ceased.

### System strength

#### **11. System strength**

11.1. Individual components of plant within a generating system, which includes but is not limited to generating units and dynamic reactive power plant, must be capable of operating down to the following levels at the high voltage terminals in relation to each component:

- (a) minimum short circuit ratio of 1.5, and
- (b) minimum positive sequence X/R ratio of 2.

### Active power control capability

#### **12. Active power control capability**

<sup>12</sup> For synchronous generators, consideration will be given to the physical limitations of the plant. This may require a variation to this condition, to be determined by the Commission at the time of issuing of the licence.

- 12.1. The generating system must be capable of automatically providing a proportional increase or decrease in active power output, in response to falling and rising power system frequency respectively.
- 12.2. To comply with clause 12.1:
  - (a) An active power response to changing power system frequency must be provided with no delay, beyond that required for stable operation, or inherent in the plant controls, once frequency leaves the deadband.
  - (b) The steady state droop setting of the active power response must be adjustable in the range 2 percent to 10 percent.
  - (c) The frequency deadband for the active power response must be adjustable in the range from 0 to +/- 1.0 Hz.
- 12.3. The generating system must be capable of sustaining a response to abnormal frequency conditions for at least 10 minutes, subject only to energy resource availability for intermittent generating systems.
- 12.4. The generating system must be capable of applying different deadband and droop settings in response to rising and falling frequency and for different levels of frequency change.

### **13. Active power control capability (AGC capability)**

- 13.1. The generating system must have active power control capabilities that allow it to participate in existing national electricity market arrangements requiring automatic generation control (**AGC**).
- 13.2. At a minimum, the AGC must have the capability to:
  - (a) receive and respond to a remotely determined active power control setpoint, updated at a rate of every four seconds, transmitted to the generating system, and
  - (b) provide the following information to AEMO, upon a request from AEMO under NER clauses S5.2.6.1 or 3.8.2:
    - (i) actual active power output;
    - (ii) maximum raise limit;
    - (iii) minimum lower limit;
    - (iv) maximum raise ramp rate; and
    - (v) maximum lower ramp rate.

### **14. Active power control capability (rate of change of active power)**

- 14.1. The generating system must be capable of limiting the rate of change of active power, both upwards and downwards. A generating system is not required to comply with a limit on the

rate of reduction of active power where the reduction in active power is caused by energy resource availability for intermittent generating systems.

- 14.2. The generating system must be capable of implementing different active power rate limits for operation in the normal operating frequency band and for contingency events.
- 14.3. The generating system must be capable of setting a ramp rate limit with accuracy of within 10 percent.

#### **15. Active power control capability**

- 15.1. The generating system must have the capability to provide real-time information about its active power control settings to AEMO, including mode of operation, deadband and droop parameters and any other active power control setting that may change during real-time operation.

### System restoration

#### **16. System restoration**

- 16.1. Where sufficient minimum fault level is available from online synchronous machines, the generating system must have the following capability in the event of a black system:
  - (a) the generating system must be capable of operation with auxiliary loads only for X minutes<sup>13</sup> while system load is being restored, and
  - (b) the generating system, including, but not limited to, each of its generating units and dynamic reactive power support plant (as applicable) must have the capability to provide steady-state and dynamic reactive power when operating with auxiliary loads only for X minutes while system load is being restored.<sup>14</sup>

---

<sup>13</sup> The exact duration will be specified by the Commission at the time the licence is issued.

<sup>14</sup> The exact duration will be specified by the Commission at the time the licence is issued.



The Essential Services Commission  
Level 1, 151 Pirie Street Adelaide SA 5000  
GPO Box 2605 Adelaide SA 5001

T 08 8463 4444

E [escosa@escosa.sa.gov.au](mailto:escosa@escosa.sa.gov.au) | W [www.escosa.sa.gov.au](http://www.escosa.sa.gov.au)

