



Application form for the issue of an Electricity Generation Licence

by the Essential Services Commission of SA
under the Electricity Act 1996

August 2017

Enquiries concerning this application form should be addressed to:

Essential Services Commission
GPO Box 2605
Adelaide SA 5001

Telephone: (08) 8463 4444
Freecall: 1800 633 592 (SA and mobiles only)
E-mail: escosa@escosa.sa.gov.au
Web: www.escosa.sa.gov.au

Table of contents

Licence requirements and conditions	1
Generation operations which require a licence	1
Mandatory licence conditions	1
Additional technical licence conditions	2
Annual licence fees	2
Use of this form and applicant's responsibilities	3
Application fees	3
How to lodge an application	3
Consultation and Confidentiality	4
Further information	4
Licence Application Form	1
1 The Applicant	1
1.1 Identity of Applicant	1
1.2 Legal Identity of Applicant	1
1.3 Address and Contact Details of Applicant	1
1.4 Contact Person on behalf of Applicant	1
1.5 Contact Person for Licence Fees	2
1.6 Diagram of Corporate or other Structure	2
2 The Licence	3
2.1 Date from which Licence is sought	3
2.2 Nature and scope of operations for which Licence is sought	3
3 Suitability of applicant to hold a licence	4
3.1 Standard of honesty and integrity shown by Applicant	4
3.2 Standard of honesty and integrity shown by Officers and major shareholders of Applicant	5
3.3 Names and addresses of the Officers of Applicant	5
3.4 Names and addresses of major shareholders of Applicant	6
3.5 Details of the group members	6
3.6 Additional information	6
3.7 Financial resources available to the Applicant	7
3.8 Additional Details of Structure of Applicant	8
3.9 Human resources available to the Applicant	8
3.10 Technical resources available to the Applicant	8
3.11 Quality of Electricity Produced/Connection Agreement	9
3.12 Risk Management	9
3.13 Development Act Approval	10
3.14 Registration with AEMO	10

3.15	Licences held by the Applicant in other Australian jurisdictions	10
3.16	Previous unsuccessful licence applications in other Australian jurisdictions	11
3.17	Licences held by Associates of the Applicant	11
3.18	Compliance Plans	11
3.19	Additional Information	12
4	Factors specified in the Essential Services Commission Act 2002	13
5	Application fees	13
6	Declaration	14
	Attachment 1	15
	2017 model licence conditions for new generators	15
	Interpretation of this schedule	15
	Disturbance ride through capability	15
	Voltage control capability	18
	System strength	19
	Active power control capability	19
	System restoration	20

Licence requirements and conditions

It is essential that licence applicants read the Essential Services Commission's (Commission) Advisory Bulletin No 4 – "*Licensing Arrangements for the Electricity and Gas Supply Industries*" before they fill out this form. This Bulletin is available on the Commission website www.escosa.sa.gov.au under electricity/licensing.

Generation operations which require a licence

Section 15(2)(a) of the *Electricity Act 1996* (Act)¹ is explicit in that it requires a person that carries on the operation of the generation of electricity to hold a licence. This requirement applies to all generators with the exception of a generator that can rely on:

- (1) one of the statutory exemptions specified in the Electricity (General) Regulations 1997 (Regulations) outlined below;
- (2) an individual exemption issued by the Commission (with the approval of the Minister) pursuant to section 80(1) of the Act; or
- (3) an exemption made by Governor under a regulation pursuant to section 98(2)(e) of the Act.

Pursuant to Regulations 6(1) and (2), the following generators are exempt from the requirement to hold a generation licence:

- ▶ a generator whose generating plant has a rated nameplate output of 100kVA or less;
- ▶ a generator that does not supply electricity for reward to or by means of a transmission or distribution network;
- ▶ a generator that generates electricity for the sole consumption of that generator or a designated body (such bodies must be designated by the Minister²); or
- ▶ a generator that generates electricity for a person at a premises occupied or used by the person as a tenant or licensee (whether directly or indirectly) of the generator (or a designated body) where that person is not charged for the supply of electricity except by a licensed retailer/generator or as an unspecified part of rent or charges for the occupation or use of the premises.

It is important for generators (or proposed generators) to carefully consider whether they can rely on a statutory exemption from the requirement to be licensed. If the reliance on a statutory exemption is queried by the Commission, the onus to provide evidence that a particular exemption can be relied upon is on the relevant generator.

In addition, in the event that the operations of a generator change so that it can no longer rely on one of the three exemptions specified above, it will need to apply to the Commission for a generation licence immediately in order to continue those operations.

Mandatory licence conditions

Sections 21(1) and 22 of the Act requires the Commission to place certain mandatory conditions in generation licences. The Commission strongly recommends that applicants review these mandatory conditions. Applicants must be familiar with the relevant conditions and confident that they can comply with the conditions.

¹ Available at <https://www.legislation.sa.gov.au/L Z/C/A/ELECTRICITY%20ACT%201996.aspx>

² To date, the Minister for Energy and Resources has not designated any bodies for the purposes of Regulations 6(1).

Additional technical licence conditions

Additional technical licence conditions apply to all new electricity generators seeking to connect to the South Australian power system. Applicants for a generation licence should familiarise themselves with the Commission's Inquiry into the licensing arrangements for generators in South Australia final report, available on the Commissions website.³

Model licence conditions reflecting the Inquiry findings and conclusions have been developed and are available in Appendix 1. The model conditions will be applicable to all new applications, having regard to advice from the Australian Energy Market Operator (AEMO) on the specific circumstances of individual applications received.

Depending on the specific characteristics of a given generation project, the model conditions may be varied to the degree necessary to ensure that South Australian consumers' long-term interests with respect to the price, quality and reliability of electricity services are protected.

Annual licence fees

Holding a licence incurs annual licence fees. The licence fees determined by the Minister for Resources and Energy are administered by the Commission. At annual intervals, the Commission, on behalf of the Minister, will send to each licensee, depending on the category within the sector, an invoice for the licence fee. Licence fees are to be paid on receipt of an invoice via one of the payment options set out in the invoice.

The initial licence will not be issued until the first annual licence fee (or approved licence fee instalment) has been paid.

³ Refer: <http://www.escosa.sa.gov.au/projects-and-publications/projects/inquiries/inquiry-into-licensing-arrangements-under-the-electricity-act-1996-for-inverter-connected-generators/inquiry-into-licensing-arrangements-under-the-electricity-act-1996-for-inverter-connected-generators>

How to apply for a generation licence

This form is to be completed by persons making application to the Commission for the issue of a licence to authorise electricity generation operations in the electricity supply industry in South Australia.

The Commission can also consider joint applications from two or more persons who wish to hold a licence jointly. Persons making joint applications must ensure that each of the applicants completes a separate application form, together with a covering letter explaining that the application is for a licence to be jointly held.

Section 16(1)(a) of the Act provides that an application for the issue of a licence must be made to the Commission in a form approved by the Commission. This is the form approved by the Commission.

Use of this form and applicant's responsibilities

An application for a licence may be made by any legal person including, without limitation, individuals, partnerships, incorporated associations, unit and other forms of trusts and corporations. Entities that are not a legal person (for example, an unincorporated joint venture) cannot apply for a licence.

For the purpose of this application form, reference to the term "Officer" include the applicant's directors and secretary, and other persons who make or participate in making decisions that affect a substantial part of the business of the applicant (e.g. Chief Executive Officer, Chief Financial Officer, General Manager etc.).

Applicants should list the information requested in the spaces provided in this form and enclose additional information when required. Applicants must take all reasonable steps to ensure the information provided in the application form is complete, true and correct and are required to make a declaration to that effect in the application form. Failure to disclose information or misrepresent any matter relevant to such information may result in a licence not being issued or in the suspension or cancellation of a licence at a later time.

Applicants are responsible for providing the Commission with current, accurate and relevant documentation. This will ensure that the application is processed promptly and without delay. All applications are assessed on a case-by-case basis. If insufficient information is provided with an application, the Commission will request additional information to be submitted before the application is considered further.

Application fees

Applicants should also enclose the application fee (presently set by the Minister for Resources and Energy at \$1,000 per licence) with their application.

How to lodge an application

Applicants should send their completed application form in writing and electronically.

- ▶ In writing to: Essential Services Commission of SA
GPO Box 2605
Adelaide SA 5001
- ▶ Electronically to: licensing@escosa.sa.gov.au

Consultation and Confidentiality

The Commission will consult with relevant government, industry and consumer groups in the conduct of its licensing functions through a public consultation process. Consequently, applications and/or supporting information will be made available on the Commission's website and in hard copy from the Commission's office for this purpose.

If applicants believe that they are providing confidential information when completing this form they should write "this information is confidential" after any such information. It is the applicant's responsibility to ensure this is clearly highlighted on the form. Applicants should also provide a 'non-confidential' version of the form capable of publication on the Commission's website.

The Commission will use information supplied in applications and in support of applications in accordance with the requirements of Part 5 of the Essential Services Commission Act 2002. Applicants claiming confidentiality are encouraged to familiarise themselves with Part 5. Applicants should note that the Commission may disclose confidential information in some circumstances.

Further information

Applicants should note that the Commission may ask applicants who have submitted an application form to provide further information to the Commission, or to clarify the information that they have already provided if required.

Please note that, in the event that an application lacks sufficient detail and the Commission is required to request additional information from an applicant, delays in the assessment of the application may occur.

Licence Application Form

1 The Applicant

Applicants must answer all questions in this section.

1.1 Identity of Applicant

State the full name of the applicant. The applicant is the person who will be undertaking the electricity generation operations that will be the subject of the licence. Joint applicants should each complete an application form, and submit their application forms at the same time, with a covering letter explaining that a joint application is being made.

Name: Venergy Pty Ltd

1.2 Legal Identity of Applicant

Provide information about the applicant, (i.e. whether the applicant is a natural person, private limited company or partnership, etc). If the applicant is a body corporate, please also state the jurisdiction in which the applicant is registered, and the applicant's ABN/ACN.

Venergy Pty Ltd (88 139 522 213) is an Australian Proprietary Company, Limited By Shares

1.3 Address and Contact Details of Applicant

Business Address: 664 South Rd, Glandore
State: South Australia, 5037
Telephone: 1800 836 374
E-mail: info@veneryaaustralia.com.au

1.4 Contact Person on behalf of Applicant

The full name, title and contact details of a person to whom the Commission can direct enquiries and correspondence about the application.

Full Name: Nodsmil Sescar
Title: Head Engineer
Business Address: 664 South Rd, Glandore

State: South Australia, 5037
Telephone: 1800 836 374 | 0499 888 174
E-mail: nodsmil.sescar@venergyaustralia.com.au

1.5 Contact Person for Licence Fees

The full name and/or title of the person to whom the Commission can direct enquiries and correspondence about licence fees.

Full Name: Kristine Acopiado
Title: Executive Coordinator
Business Address: 664 South Rd, Glandore
State: South Australia, 5037
Telephone: 1800 836 374 | 08 8125 9605
E-mail: accounts@venergyaustralia.com.au

1.6 Diagram of Corporate or other Structure

Please attach with this application form details of the corporate or other structure, including details of any related companies within the meaning of the Corporations Act 2001; and a diagram of the organisational chart, including composition of the board, management and other key personnel responsible for the key functions of the business.

Venergy Pty Ltd (88 139 522 213) is an Australian Proprietary Company, Limited By Shares and a subsidiary of Solven Holdings Pty Ltd.

Please refer to [1.6.1 Venergy Organizational Chart](#)

2 The Licence

Applicants must answer all questions in this section.

2.1 Date from which Licence is sought

Applicants should usually allow the Commission a minimum of 12 weeks to consider an application, as a public consultation period of at least four weeks forms part of the Commission's consideration of licence applications. If the applicant seeks to have the licence issued by a certain date, provide this date. Please note that the Commission does not undertake to issue the licence by this date.

1 November 2019

2.2 Nature and scope of operations for which Licence is sought

Applicants for a generation licence must state the location of the generation plant, the expected name plate capacity of the generation plant, the type of generation and fuel used and some details about how the generator is to be connected to the network. Applicants for a wind generation licence must attach a map showing the location of the wind turbines.

Grid Connected Solar PV

Grundfos Pumps Pty Ltd, 515 South RD, Regency Park SA 5010

Total DC Capacity: 427.36 kWp

Total AC Capacity: 450.0 kVA

LGC Claim

DC Capacity: 327.36 kWp

AC Capacity: 350.0 kVA

Details:

- 1056x Trina TSM310-DD05A.08(II)
- 7x SMA Core 1 STP 50-40

STC Claim

DC Capacity: 100.0 kWp

AC Capacity: 100.0 kVA

Details:

- 4x SMA STP-25000TL-30

3 Suitability of applicant to hold a licence

Applicants must answer all questions in this section.

3.1 Standard of honesty and integrity shown by Applicant

In deciding whether the applicant is a suitable person to hold a licence, the Commission may:

- ▶ consider the applicant's previous commercial and other dealings, and
- ▶ the standard of honesty and integrity shown in those dealings.

Please provide information that will assist the Commission in its consideration of this matter. If the applicant:

- ▶ has been found guilty of any criminal offence,
- ▶ has been successfully prosecuted under any Territory, State or Commonwealth legislation (such as the Australian Securities and Investments Commission Act 2001 or the Competition and Consumer Act 2010) or
- ▶ has been the subject of disciplinary action,
- ▶ has been the subject of any past or present administrative or legal actions in relation to an authorisation, authority, or licence in any industry,

details of such matters must be disclosed. Failure to disclose such information or misrepresent any matter relevant to such information may result in the cancellation of a licence.

The Commission may use the service of an external expert to assist with the assessment of the applicant's standard of honesty and integrity.

Venergy's management and employees are at all times expected to: uphold the law; act with integrity; and exercise professionalism. Within the organisation, all employees are subject to the adherence to the code of conduct.

Venergy has once been subjected to one (1) court action, details as follows:

Date: 24 July 2015

Case Number: 234/15

Amount: \$6,850.00

Court: Magistrates Court Judgments - Ipswich & Warwick.

Outcome: Matter has been resolved and set aside, per [3.1.1 Equifax Correction Letter](#).

3.2 Standard of honesty and integrity shown by Officers and major shareholders of Applicant

Applicants should address responses to this question in the same manner as 3.1 above except here it relates to officers and major shareholders of the applicant.

Please also supply details of any policies and procedures addressing the probity and competence of officers and other key management staff.

Venergy's management and key officers:

1. have not been found guilty of any criminal offence;
2. have not been successfully prosecuted under any Territory, State or Commonwealth legislation (such as the Australian Securities and Investments Commission Act 2001 or the Competition and Consumer Act 2010); and
3. have not been the subject of disciplinary action or of any past or present administrative or legal actions in relation to an authorisation, authority, or licence in any industry.

Further, Venergy's believes that its management and key officers have adequate experience and are competent to manage a generation licence, per [3.2.1 Venergy Corporate Capability Statement](#).

3.3 Names and addresses of the Officers of Applicant

State the names and addresses of the officers of the applicant. "Officers" of the applicant include the applicant's directors and secretary, and other persons who make or participate in making decisions that affect a substantial part of the business of the applicant.

Full Name: Timothy James Vorbach

Date of Birth:

Office Held: Director

Address:

State: South Australia

Post Code:

Full Name: Matthew Luke Wilkins

Date of Birth:

Office Held: Chief Executive Officer

Address: c/o Venergy
664 South Rd, Glandore

State: South Australia

Post Code: 5037

(attach additional pages if necessary)

3.4 Names and addresses of major shareholders of Applicant

State the full names and addresses of the major shareholders of the applicant

Full Name: Timothy James Vorbach

Date of Birth:

Office Held: Director

Address:

State: South Australia

Post Code:

Full Name: Matthew Luke Wilkins

Date of Birth:

Office Held: Chief Executive Officer

Address: c/o Venergy
664 South Rd, Glandore

State: South Australia

Post Code: 5037

3.5 Details of the group members

This is information about entities controlled by the applicant, or by the ultimate parent entity of the applicant (if applicable).

Immediate parent: Solven Holdings Pty Ltd

3.6 Additional information

Please answer the following questions.

- Is the applicant a resident of, or does it have permanent establishment in, Australia?
Where the answer to this question is no, please provide further detail.

Yes

- Is the applicant under external administration (as defined in the Corporations Act 2001) or under a similar form of administration under any laws applicable to it in any jurisdiction? Where the answer to this question is yes, please provide further detail.

No

- ▶ Is the applicant immune from suit in respect of the obligations under the Electricity Act 1996? Where the answer to this question is yes, please provide further detail.

No

- ▶ Is the applicant capable of being sued in its own name in a court of Australia? Where the answer to this question is no, please provide further detail.

Yes

(attach additional pages if necessary)

3.7 Financial resources available to the Applicant

Provide information about the financial resources available to the applicant. If the applicant is a company, please also enclose:

- ▶ copies of all audited profit and loss statements and balance sheets for the last three financial years (including all notes), and
- ▶ director's declaration that the financial statements comply with accounting standards, give a true and fair view, have been made in accordance with the Corporations Act and that there are reasonable grounds to believe the company/entity will be able to pay its debts as and when they fall due; and
- ▶ the director's report and the audit opinion.

If the applicant is a subsidiary company, please also provide:

- ▶ copies of all audited profit and loss statements and balance sheets of the applicant's parent company for up to the last three financial years.

The applicant should also submit copies of:

- ▶ its business plans including at least strategic direction and objectives, identified opportunities in the market place and forecast results; and
- ▶ evidence of capital and liquidity support in place, including any bank or cross guarantees, to support the business and evidence of negotiations with the network service provider concerning credit support arrangements.

Please refer:

[3.7.1 Financial Report 2017/18](#)

[3.7.2 Financial Report 2016/17](#)

[3.7.3 Financial Report 2015/16](#)

3.8 Additional Details of Structure of Applicant

If the applicant is part of a group of related companies, and/or party to a partnership, joint venture or alliance agreement with another company, please provide:

- ▶ contractual arrangements (e.g. alliance contracts, associate contracts, establishment contracts) that define relationships within the group – including shared resources, guarantees, revenue flows, obligations and or responsibilities.

Not applicable

3.9 Human resources available to the Applicant

Provide information about the human resources available to the applicant. This includes:

- ▶ the experience and qualifications of those employees outlined in the organisational chart (see point 1.6); and
- ▶ if the applicant will employ contractor/s to assist with the licensed operations, the name of that contractor/s, details about the experience of the contractor/s in such operations and details of the processes in place to ensure the contractor/s complies with the regulatory obligations imposed by the licence.

Please refer to :

1.6.1 Venergy Organizational Chart; and

3.2.1 Venergy Corporate Capability Statement

3.10 Technical resources available to the Applicant

Applicants for a generation licence are asked to provide details about the availability of technical resources to be used in carrying out the operations for which a licence is sought. The information should include details about the technically qualified staff available to the applicant and (if relevant) details of experience gained in similar operations.

Where applicants are relying on a third party to provide staff and resources to meet the technical requirements of the generation licence, please provide:

- ▶ a list of all functions and activities being proposed to outsource;
- ▶ details of any formal agreement/s to provide services, including confirmation that the third party possess relevant technical competencies to conduct the proposed activities;
- ▶ a summary of the third party's technical capacity to meet relevant obligations, including relevant accreditations; and

- a summary of the third party's experience and knowledge in the relevant area.

The PV generation system has already been installed upon receipt of approved solar design and Connection Approval from SA Power Networks.

Venergy has in-house installers/electricians and electrical engineers to maintain and service the solar PV system.

Further, Venergy is an approved retailer by the Clean Energy Regulator to create and trade Large Scale Certificates (LGCs), per [3.10.1 REC Registry Account](#).

3.11 Quality of Electricity Produced/Connection Agreement

The Commission may not issue a generation licence unless it is satisfied that the generating plant (or proposed generating plant) will generate electricity of the appropriate quality for the relevant transmission or distribution network. The Commission will be satisfied that the electricity is of an appropriate quality if the applicant has entered into a connection agreement which meets the Commission's technical requirements with the licensed operator of the relevant transmission or distribution network. Applicants are therefore required to submit a copy of such a connection agreement.

Please refer to [3.11.1 SAPN Negotiated Connection Offer](#)

3.12 Risk Management

Provide confirmation and reasonable evidence that the applicant's management has identified the risks associated with electricity operations and has established, utilises and relies upon risk management systems and processes which are adequate, accurate and current to address those risks. A copy of the applicant's risk management strategy should be submitted.

Please refer to:

[3.12.1 Risk Management Framework](#); and
[3.12.2 SAPN Engineering Report](#)

3.13 Development Act Approval

Please advise if the applicant has or is applying for approval under the Development Act 1993 (SA). If so, provide details, including the date on which approval was or will be granted.

The generating plant being applied is exempted as per Schedule 1A Item 10 of South Australia Development Regulation of 2008

3.14 Registration with AEMO

Please advise if the applicant will apply to register with AEMO. If so, provide details. Applicants for a wind generation licence should note that registration as a semi-scheduled market participant is required for all new generators and all expansions to existing wind generation plant.

Not applicable

3.15 Licences held by the Applicant in other Australian jurisdictions.

If the applicant holds, or has previously held, electricity and/or gas licences in other Australian jurisdictions please provide details. If a licence previously held has been suspended or cancelled, please provide details.

Solar Power Station at The Pines Shopping Centre accredited by the Clean Energy Regulator.

3.16 Previous unsuccessful licence applications in other Australian jurisdictions

Please state whether the applicant has applied for an electricity or gas licence in another Australian jurisdiction and not been issued with a licence, and provide details if relevant.

Not applicable

3.17 Licences held by Associates of the Applicant

If an associate of the applicant (within the meaning of the Corporations Act) holds an electricity or gas licence in South Australia or in other Australian jurisdictions, please provide details.

Not applicable

3.18 Compliance Plans

Applicants are required to submit a copy of their Compliance Plan which demonstrates how the compliance systems the applicant has (or will have) in place will ensure compliance with all of the applicable regulatory obligations imposed by the relevant licence.

3.19 Additional Information

The Commission encourages applicants to provide any additional information they consider would be of assistance in supporting the application. Please provide below.

This image shows a full page of blank primary-ruled paper. It features multiple sets of horizontal lines designed to help young learners write neatly. Each set consists of three lines: a solid top line, a dashed middle line, and a solid bottom line. These sets are repeated down the entire page, providing ample space for handwriting practice. The paper is white, and the lines are printed in a light blue or grey color. There are no margins, text, or other markings on the page.

4 Factors specified in the Essential Services Commission Act 2002

In considering a licence application, the Commission must have as its primary objective protection of the long term interests of consumers with respect to the price, quality and reliability of electricity supply, and must also have regard to the need to:

- (a) promote competitive and fair market conduct;
- (b) prevent misuse of monopoly or market power;
- (c) facilitate entry into relevant markets;
- (d) promote economic efficiency;
- (e) ensure consumers benefit from competition and efficiency;
- (f) facilitate maintenance of the financial viability of regulated industries and the incentive for long term investment;
- (g) promote consistency in regulation with other jurisdictions.

If the applicant believes that information about their application would assist the Commission in its consideration of these factors, the applicant should provide such information below.

All pointers above are agreed as a common industry practice.

5 Application fees

Applicants for a licence must pay to the Commission an application fee fixed by the Minister for Energy from time to time. This fee is presently set at \$1,000 per licence. Please enclose this fee with the application. An application cannot be considered until this fee has been received and cannot be refunded.

6 Declaration

All information in this application for the issue of a licence to authorise electricity generation operations in the electricity supply industry in South Australia must be verified by a Statutory Declaration of the applicant, in accordance with the provisions of the *Oaths Act 1936* (SA)⁴, stating that the information contained in the application is true and correct to the best of the applicant's knowledge, information and belief.

Where the applicant is a body corporate, evidence of the relevant authority of the declarant to sign on behalf of the body corporate must also be provided to the Commission.⁵

Statutory Declaration

I Matthew Wilkins

of Venergy Pty Ltd

do solemnly and sincerely declare that the information contained in this Application for the issue of a licence to authorise electricity generation operations in the electricity supply industry in South Australia is true and correct to the best of my knowledge information and belief.

And I make this solemn declaration conscientiously believing the same to be true, and by virtue of the provisions of the *Oaths Act 1936*.

Date 23/09/2019


Signature



(Where the applicant is a body corporate, the declaration must be made by a person authorised by body corporate to sign on its behalf)

Declared at: Hawthorn this 6th day of April 2021

Before me:



(Signature of Justice of the Peace or other person authorised under the *Oaths Act 1936*)

FRASER HUGO LAMB
A Commissioner for taking
affidavits in the Supreme Court
of South Australia

⁴ or equivalent legislation in other Australian jurisdictions.

⁵ The Commission will accept a copy of a Board minute (or circulating resolution) giving approval for the declarant to sign on behalf of the applicant as evidence of the relevant authority.

Attachment 1

2017 model licence conditions for new generators

Interpretation of this schedule

1. Interpretation

1.1. Terms used in this schedule and also in the National Electricity Rules (NER) have the same meaning in this schedule as they have in those rules (unless otherwise specified or unless the context otherwise requires).

1.2. For the purposes of this schedule, the term:

Commission - means the Essential Services Commission, established under the Essential Services Commission Act 2002.

continuous uninterrupted operation means that, for voltage disturbances within the continuous operating range (that is, connection point voltage fluctuating within 90 percent and 110 percent of normal voltage), active power must be maintained (unless there has been a change in the intermittent power source) and reactive power must be managed to meet voltage control requirements.

Disturbance ride through capability

2. Disturbance ride through capability – general requirements

2.1. The non-synchronous generating system must meet the following requirements:

- (a) The low voltage ride-through activation threshold (LVRT), as measured at the low voltage (LV) terminals of the generating units and dynamic reactive support plant (as applicable), must not be less than 85 percent of nominal voltage.
- (b) The generating system must maintain continuous uninterrupted operation for voltage disturbances as specified in clauses 3, 7 and 8.
- (c) Where LVRT and high voltage ride-through (HVRT) requirements in the NER are specified in respect of the generating system's connection point, the withstand capability of individual generating units is to be determined at the LV side of the generating unit's transformer. All individual generating units must remain connected for connection point voltages within the LVRT/HVRT withstand requirements, irrespective of the generating system's transformer tap position.

3. Disturbance ride-through (reactive current injection)

3.1. The generating system must supply additional capacitive reactive current (reactive current injection) of up to 4 percent of the maximum continuous current of the generating system (in the absence of a disturbance) for each 1 percent reduction of connection point voltage below 90 percent of normal voltage, as shown in Table 1. This requirement applies at the LV terminals of the generating units and dynamic reactive support plant (as applicable) for

power system disturbances resulting in a voltage reduction of up to 100 percent of normal voltage at the connection point.

- 3.2. The generating system must supply additional inductive reactive current (reactive current absorption) of up to 6 percent of the maximum continuous current of the generating system (in the absence of a disturbance) for each 1 percent increase in connection point voltage above 110 percent of the normal voltage, as shown in Table 1. This requirement applies at the LV terminals of the generating units and dynamic reactive support plant (as applicable).
- 3.3. The reactive current injection must be maintained until the connection point voltage returns to within the range of 90 percent to 110 percent of normal voltage.

Table 1: Reactive current injection requirements

Reactive current response	Current injection gain (%)	Current absorption gain (%)	Minimum amount of contribution as percentage of rated current	Speed of contribution	
				Rise time (millisecond)	Settling time (millisecond)
Synchronous	4	6	250	30	N/A
Non-synchronous	4	6	100	30	60

- 3.4. The amount of reactive current injection required may be calculated using phase-to-phase, phase-to-ground, or sequence components of voltage. For the last method, the ratio of negative-sequence to positive-sequence current injection must be X.⁶
- 3.5. The generating system must comply with the following response characteristics for reactive current injection:
 - (a) A rise time no greater than 30 milliseconds and a settling time no greater than 60 milliseconds applies to reactive current injection requirements.⁷
 - (b) The reactive current injection requirements described above apply for all pre-disturbance reactive power control modes (voltage control, power factor control and reactive power control).⁸
 - (c) The reactive current response must be adequately damped as defined in the NER.
 - (d) Upon occurrence of a fault, reactive power consumption must not exceed 5 percent of maximum continuous rated current of the generating system and must be limited to the rise time duration set out in Table 1.
 - (e) The post-fault reactive power contribution of the generating system must be sufficient to ensure that the connection point voltage is within the following ranges for continuous uninterrupted operation:
 - (i) voltages over 110 percent for the durations permitted under NER clause S5.1a.4;

⁶ The exact ratio of negative-sequence to positive-sequence current injection will be specified by the Commission at the time the licence is issued.

⁷ The settling time requirement does not apply to synchronous generators.

⁸ This requirement does not apply to synchronous generators.

- (ii) 90 percent to 110 percent of normal voltage continuously;
- (iii) 80 percent to 90 percent of normal voltage for a period of at least 10 seconds; and
- (iv) 70 percent to 80 percent of normal voltage for a period of at least 2 seconds.

4. Disturbance ride through (active power injection requirements)

- 4.1. The generating system must be capable of restoring active power to at least 95 percent of the level existing just prior to a fault within X milliseconds after disconnection of the faulted element.⁹
- 4.2. Upon occurrence of a fault, a generating system's transient active power consumption must not exceed one power frequency cycle and must not exceed 5 percent of the maximum continuous rated current of the generating system.

5. Multiple low voltage disturbance ride-through

- 5.1. The generating system, including, but not limited to, each of its generating units and dynamic reactive power support plant, must be capable of withstanding both of the following within a five minute interval:
 - (a) Any combination of voltage disturbances causing the voltage at the respective low voltage (LV) terminals of the equipment to drop below 85 percent of the nominal voltage for a total duration of 1,500 milliseconds regardless of disturbance type, duration, and residual voltage at the generating unit's terminals. The total number of voltage disturbances for which successful ride-through is required is limited to 15. Each fault can be a solid fault resulting in 100 percent voltage drop at the connection point with duration not exceeding the longest time expected to be taken for the breaker fail protection system to clear the fault, as set out in Table S5.1a.2 of the NER.
 - (b) A single worst-case long-duration shallow voltage disturbance, causing the voltage at the connection point to drop to 70- 80 percent of the normal voltage for a total duration of 2,000 milliseconds.
- 5.2. Subject to compliance with the requirements in clause 5.1, the generating system, including, but not limited to, each of its generating units and dynamic reactive power support plant, is not required to withstand any additional voltage variation exceeding ± 10 percent of nominal voltage experienced at the respective LV terminals within 30 minutes from the commencement of the first variation.¹⁰

6. Disturbance ride-through (high voltage disturbance ride-through)

- 6.1. The generating system must have a level of over-voltage withstand capability consistent with the levels shown in Table 2.¹¹

⁹ The exact active power recovery time will be specified by the Commission at the time the licence is issued and will be between 100 and 500 milliseconds.

¹⁰ For synchronous generators, consideration will be given to the physical limitations of the plant. This may require a variation to this condition, to be determined by Commission at the time of issuing of the licence.

¹¹ Unless otherwise specified by the Commission at the time the licence is issued.

- 6.2. The generating system must maintain continuous uninterrupted operation for temporary over voltage durations as specified in Table 2.

Table 2: Required over voltage withstand capability

Temporary overvoltage (% of normal voltage)	110–115	>115–120	>120–125	>125–130	>130–140
Duration(s)	1,200	20	2	0.2	0.02

7. Disturbance ride-through (partial load rejection)

- 7.1. The non-synchronous generating system must be capable of continuous uninterrupted operation during and following a power system load reduction of 30 percent from its pre-disturbance level or equivalent impact from separation of part of the power system in less than 10 seconds, provided that the loading level remains above minimum load.

8. Disturbance ride-through (frequency disturbance ride-through)

- 8.1. The generating system must be capable of continuous uninterrupted operation for any combination of the following rates of change of frequency:
- (a) ± 4 Hz/s for 250 milliseconds
 - (b) ± 3 Hz/s for 1 second, until such time as power system frequency breaches the extreme frequency excursion tolerance limits.¹²

9. Disturbance ride-through (voltage phase angle shift)

- 9.1. The generating system must not include any vector shift or similar relay/protective function acting upon voltage phase angle which might operate for phase angle changes less than 20 degrees.

Voltage control capability

10. Voltage control capability

- 10.1. The generating system must be capable of being controlled by a fast-acting, continuously variable, voltage control system which must be able to receive a local and remote voltage set point.
- 10.2. The generating system must be capable of operating at either a set reactive power level or a set power factor, which must be able to be set locally or remotely at any time.
- 10.3. The voltage, power factor and reactive power control mode of the generating system must be capable of:
 - (a) being overridden by the disturbance ride through requirements specified in clauses **Error! Reference source not found.** to 9 (inclusive) during power system voltage disturbances, and

¹² For synchronous generators, consideration will be given to the physical limitations of the plant. This may require a variation to this condition, to be determined by the Commission at the time of issuing of the licence.

- (b) automatically reverting to power factor or reactive power mode when the disturbance has ceased.

System strength

11. System strength

- 11.1. Individual components of plant within a generating system, which includes but is not limited to generating units and dynamic reactive power plant, must be capable of operating down to the following levels at the high voltage terminals in relation to each component:
 - (a) minimum short circuit ratio of 1.5, and
 - (b) minimum positive sequence X/R ratio of 2.

Active power control capability

12. Active power control capability

- 12.1. The generating system must be capable of automatically providing a proportional increase or decrease in active power output, in response to falling and rising power system frequency respectively.
- 12.2. To comply with clause 12.1:
 - (a) An active power response to changing power system frequency must be provided with no delay, beyond that required for stable operation, or inherent in the plant controls, once frequency leaves the deadband.
 - (b) The steady state droop setting of the active power response must be adjustable in the range 2 percent to 10 percent.
 - (c) The frequency deadband for the active power response must be adjustable in the range from 0 to +/- 1.0 Hz.
- 12.3. The generating system must be capable of sustaining a response to abnormal frequency conditions for at least 10 minutes, subject only to energy resource availability for intermittent generating systems.
- 12.4. The generating system must be capable of applying different deadband and droop settings in response to rising and falling frequency and for different levels of frequency change.

13. Active power control capability (AGC capability)

- 13.1. The generating system must have active power control capabilities that allow it to participate in existing national electricity market arrangements requiring automatic generation control (AGC).
- 13.2. At a minimum, the AGC must have the capability to:
 - (a) receive and respond to a remotely determined active power control setpoint, updated at a rate of every four seconds, transmitted to the generating system, and

- (b) provide the following information to AEMO, upon a request from AEMO under NER clauses S5.2.6.1 or 3.8.2:

- (i) actual active power output;
- (ii) maximum raise limit;
- (iii) minimum lower limit;
- (iv) maximum raise ramp rate; and
- (v) maximum lower ramp rate.

14. Active power control capability (rate of change of active power)

- 14.1. The generating system must be capable of limiting the rate of change of active power, both upwards and downwards. A generating system is not required to comply with a limit on the rate of reduction of active power where the reduction in active power is caused by energy resource availability for intermittent generating systems.
- 14.2. The generating system must be capable of implementing different active power rate limits for operation in the normal operating frequency band and for contingency events.
- 14.3. The generating system must be capable of setting a ramp rate limit with accuracy of within 10 percent.

15. Active power control capability

- 15.1. The generating system must have the capability to provide real-time information about its active power control settings to AEMO, including mode of operation, deadband and droop parameters and any other active power control setting that may change during real-time operation.

System restoration

16. System restoration

- 16.1. Where sufficient minimum fault level is available from online synchronous machines, the generating system must have the following capability in the event of a black system:
 - (a) the generating system must be capable of operation with auxiliary loads only for X minutes¹³ while system load is being restored, and
 - (b) the generating system, including, but not limited to, each of its generating units and dynamic reactive power support plant (as applicable) must have the capability to provide steady-state and dynamic reactive power when operating with auxiliary loads only for X minutes while system load is being restored.¹⁴

¹³ The exact duration will be specified by the Commission at the time the licence is issued.

¹⁴ The exact duration will be specified by the Commission at the time the licence is issued.



The Essential Services Commission
Level 1, 151 Pirie Street Adelaide SA 5000
GPO Box 2605 Adelaide SA 5001
T 08 8463 4444

E escosa@escosa.sa.gov.au | W www.escosa.sa.gov.au